
October 10, 2024

IFB SA 2502 Sewer Collection Rehabilitation & Replacement Program-UOSA Bridge

Addendum #1

THIS SOLICITATION IS HEREBY AMENDED AS FOLLOWS:

1. The attached response to question has been added for clarification.

All other solicitation terms, conditions and provisions remain unchanged and in full force and effect.

Acknowledgement: Bidders submitting a bid response for the above-named solicitation shall take note of the following changes, additions, deletions, clarification, etc., in the Contract Documents, which shall become a part of and have precedence over anything shown or described in the Contract Documents, and as such shall be taken into consideration and be included in the Bidders's response. All other terms and conditions of the Invitation for Bid shall remain unchanged.

Bidders must acknowledge receipt of this amendment by signing and returning this addendum with the proposal response or prior to the bid due date and time.

Authorized Signature

Date

Name Printed

Title

Company Name

Direct all inquiries to SAprocurement@pwwater.org

Question and Response

- 1. Question:** At the site visit it was mentioned that the overhead power line going directly over the bridge will not be relocated. Can it be de-energized?

Response: The overhead power line cannot be de-energized unless an alternate power supply is provided to the metering station, which is maintained by UOSA, not PW Water. According to the specs, the power serves a critical function at the Metering Station, and Sheet C.02 specifies protecting the existing utility pole. To perform any work near the power lines, coordination with City of Manassas Electric is necessary. Utility shut offs and relocations must be arranged with the appropriate utility companies as indicated in the specs. Temporary protections will also be required to prevent injury and facility damage.

Response: End of Addendum Number One