
July 2, 2026

IFB SA 2630, Hoadly Booster Pumping Station (F05) and Discharge Main

Addendum #2

This Addendum revises the response to **Question 2** contained in **Addendum No. 1**.

The clarification is necessary because substitution requirements were inadvertently referenced in two different sections of the solicitation—**SECTION 01 60 00 - MATERIAL AND EQUIPMENT** and **SECTION 33 14 43 - PACKAGED PUMPING SYSTEM FOR WATER UTILITY SERVICE**.

The revised response below clarifies Prince William Water's requirements.

THIS SOLICITATION IS HEREBY AMENDED AS FOLLOWS:

I. CHANGES TO THE CONTRACT SPECIFICATIONS

- a. **ADD** to Specification 33 14 43 - Packaged Pumping System for Water Utility Service Part 2.2A “Manufacturer”.

- i. “2. Precision Pumping System”

II. QUESTIONS AND ANSWERS

All other solicitation terms, conditions and provisions remain unchanged and in full force and effect.

Acknowledgement: Any Bidders submitting a bid response for the above-named solicitation shall take note of the following changes, additions, deletions, clarification, etc., in the Contract Documents, which shall become a part of and have precedence over anything shown or described in the Contract Documents, and as such shall be taken into consideration and be included in the Bidder’s response. All other terms and conditions of the Invitation for Bids shall remain unchanged.

Bidders must acknowledge receipt of this amendment by signing and returning this addendum with the bid response prior to the bid submission due date and time.

Authorized Signature

Date

Name Printed

Title

Company Name

Direct all inquiries to SAprocurements@pwwater.org

QUESTIONS AND ANSWERS

- 1.) **Question:** In Addendum No. 1, your response to Question No. 2 is confusing. Specification 33 14 43, paragraph 1.3 F specifically states that “Substitution Equipment can be considered during the pre-bid phase”. The requested information was provided. Please clarify if this equipment would be acceptable.

Revised Response: Precision Pumping System is considered equal to Excel Fluid Group, LLC. Approval of Precision Pumping System as a manufacturer does not approve the submittal, nor relieve the Contractor from adhering to all requirements of the Contract Documents. After award, the selected Contractor shall submit the Product Data to the Engineer for review in accordance with Specification 33 14 43.