



VELAP ID: 460012
VA DW ID: 00240
EPA ID: VA00050

1851 Rippon Boulevard
Woodbridge, VA 22191
703-393-2071

Average Point of Entry Analytical Report 2026

Point of Entry: 10298 Mill Street (East)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	79.0	58.2	61.1	
Aluminum		µg/L	25	BRL	BRL	BRL	
Antimony		µg/L	2	BRL	BRL	BRL	
Arsenic	10	µg/L	1	BRL	BRL	BRL	
Barium		µg/L	25	46.0	41.3	25.9	
Beryllium		µg/L	2	BRL	BRL	BRL	
Cadmium		µg/L	2	BRL	BRL	BRL	
Calcium		mg/L	1	53.2	30.2	22.6	
Chromium		µg/L	5	BRL	BRL	BRL	
Cl2, Free		mg/L	0.1		3.4		
Cl2, Total		mg/L	0.1	3.7	3.7	2.6	
Conductivity		umhos/cm	10	620.4	498.7	357.2	
Copper	1300	µg/L	25	BRL	BRL	BRL	
Hardness		mg/L	5	170.0	96.0	78.0	
Iron		µg/L	50	BRL	BRL	BRL	
Lead	15	µg/L	2	BRL	BRL	BRL	
Manganese		µg/L	2	BRL	BRL	BRL	
Molybdenum		µg/L	2	BRL	BRL	BRL	
Nickel		µg/L	5	BRL	BRL	BRL	
NO2	1	mg/L	0.02	BRL	BRL	BRL	
NO2+NO3	10	mg/L	0.2	2.3	1.2	1.0	
NO3	10	mg/L	0.18	2.3	1.2	0.9	
o-PO4		mg/L	0.05	1.4	1.4	1.4	
o-PO4 as P		mg/L	Calc	0.5	0.5	0.5	
pH		SU	1	7.5	7.2	7.1	
Selenium	50	µg/L	1	BRL	BRL	BRL	
Silver		µg/L	5	BRL	BRL	BRL	
Sodium		mg/L	1	51.3	48.0	35.9	
Temperature		°C	-10	4.1	16.1	23.8	
Thallium		µg/L	2	BRL	BRL	BRL	
Total HAA	60	µg/L	1	3.5	5.9	14.8	
Total THM	80	µg/L	0.5	4.3	11.3	18.7	
Turbidity		NTU	0.1	BRL	0.2	0.1	
Vanadium		µg/L	2	BRL	BRL	BRL	
Zinc		µg/L	25	BRL	BRL	BRL	

MCL = Maximum Contamination Level
mg/L = milligrams per liter, parts per million
SU = Standard Units
C = Celcius
µg/L = micrograms per liter, parts per billion
NTU = Nephelometric Turbidity Units
µmhos/cm = micromhos per centimeter
RL = Reporting Limit
BRL = Below Reporting Limit

Report No. 260903155055



VELAP ID: 460012
VA DW ID: 00240
EPA ID: VA00050

1851 Rippon Boulevard
Woodbridge, VA 22191
703-393-2071

Average Point of Entry Analytical Report 2026

Point of Entry: 14329 Glenkirk Road (West)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	42.8	40.6	42.9	
Aluminum		µg/L	25	BRL	25.8	41.4	
Antimony		µg/L	2	BRL	BRL	BRL	
Arsenic	10	µg/L	1	BRL	BRL	BRL	
Barium		µg/L	25	28.4	BRL	BRL	
Beryllium		µg/L	2	BRL	BRL	BRL	
Cadmium		µg/L	2	BRL	BRL	BRL	
Calcium		mg/L	1	14.9	14.8	15.2	
Chromium		µg/L	5	BRL	BRL	BRL	
Cl2, Free		mg/L	0.1		3.4		
Cl2, Total		mg/L	0.1	3.1	4.0	2.9	
Conductivity		umhos/cm	10	224.8	262.8	251.8	
Copper	1300	µg/L	25	BRL	BRL	BRL	
Hardness		mg/L	5	58.0	54.0	64.0	
Iron		µg/L	50	BRL	BRL	BRL	
Lead	15	µg/L	2	BRL	BRL	BRL	
Manganese		µg/L	2	BRL	BRL	BRL	
Molybdenum		µg/L	2	BRL	BRL	BRL	
Nickel		µg/L	5	BRL	BRL	BRL	
NO2	1	mg/L	0.02	BRL	BRL	BRL	
NO2+NO3	10	mg/L	0.2	BRL	BRL	BRL	
NO3	10	mg/L	0.18	BRL	BRL	BRL	
o-PO4		mg/L	0.05	1.0	1.2	1.2	
o-PO4 as P		mg/L	Calc	0.3	0.4	0.4	
pH		SU	1	7.6	7.4	7.6	
Selenium	50	µg/L	1	BRL	BRL	BRL	
Silver		µg/L	5	BRL	BRL	BRL	
Sodium		mg/L	1	19.1	23.5	23.0	
Temperature		°C	-10	5.1	16.8	26.0	
Thallium		µg/L	2	BRL	BRL	BRL	
Total HAA	60	µg/L	1	20.2	26.8	27.6	
Total THM	80	µg/L	0.5	26.2	35.7	41.8	
Turbidity		NTU	0.1	BRL	0.1	0.1	
Vanadium		µg/L	2	BRL	BRL	BRL	
Zinc		µg/L	25	BRL	BRL	BRL	

MCL = Maximum Contamination Level
mg/L = milligrams per liter, parts per million
SU = Standard Units
C = Celcius
µg/L = micrograms per liter, parts per billion
NTU = Nephelometric Turbidity Units
µmhos/cm = micromhos per centimeter
RL = Reporting Limit
BRL = Below Reporting Limit

Report No. 260903155055



VELAP ID: 460012
 VA DW ID: 00240
 EPA ID: VA00050

1851 Rippon Boulevard
 Woodbridge, VA 22191
 703-393-2071

Average Point of Entry Analytical Report 2026

Point of Entry: 8230 Patton Lane (West)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	120.9	90.1	77.9	
Aluminum		µg/L	25	BRL	31.0	68.6	
Antimony		µg/L	2	BRL	BRL	BRL	
Arsenic	10	µg/L	1	BRL	BRL	BRL	
Barium		µg/L	25	44.8	47.9	39.9	
Beryllium		µg/L	2	BRL	BRL	BRL	
Cadmium		µg/L	2	BRL	BRL	BRL	
Calcium		mg/L	1	55.2	39.4	36.3	
Chromium		µg/L	5	BRL	BRL	BRL	
Cl2, Free		mg/L	0.1		3.3		
Cl2, Total		mg/L	0.1	3.9	3.7	3.5	
Conductivity		umhos/cm	10	566.6	406.8	378.8	
Copper	1300	µg/L	25	BRL	BRL	BRL	
Hardness		mg/L	5	202.0	130.0	134.0	
Iron		µg/L	50	BRL	BRL	BRL	
Lead	15	µg/L	2	BRL	BRL	BRL	
Manganese		µg/L	2	BRL	BRL	BRL	
Molybdenum		µg/L	2	BRL	BRL	BRL	
Nickel		µg/L	5	BRL	BRL	BRL	
NO2	1	mg/L	0.02	0.0	BRL	BRL	
NO2+NO3	10	mg/L	0.2	1.4	0.7	1.4	
NO3	10	mg/L	0.18	1.4	0.7	1.4	
o-PO4		mg/L	0.05	1.4	1.3	1.3	
o-PO4 as P		mg/L	Calc	0.5	0.4	0.4	
pH		SU	1	7.4	7.2	7.3	
Selenium	50	µg/L	1	BRL	BRL	BRL	
Silver		µg/L	5	BRL	BRL	BRL	
Sodium		mg/L	1	36.3	19.5	20.7	
Temperature		°C	-10	4.8	16.9	26.2	
Thallium		µg/L	2	BRL	BRL	BRL	
Total HAA	60	µg/L	1	5.2	7.6	12.8	
Total THM	80	µg/L	0.5	7.0	13.5	19.0	
Turbidity		NTU	0.1	BRL	0.1	0.2	
Vanadium		µg/L	2	BRL	BRL	BRL	
Zinc		µg/L	25	BRL	BRL	BRL	

MCL = Maximum Contamination Level
mg/L = milligrams per liter, parts per million
SU = Standard Units
C = Celcius
µg/L = micrograms per liter, parts per billion
NTU = Nephelometric Turbidity Units
µmhos/cm = micromhos per centimeter
RL = Reporting Limit
BRL = Below Reporting Limit

Report No. 260903155055