



Certified Water Testing

VELAP ID: 460012 1851 Rippon Boulevard
 VA DW ID: 00240 Woodbridge, VA 22191
 EPA ID: VA00050 703-393-2071

Average Point of Entry Analytical Report 2022

Point of Entry: 10298 Mill Street (East)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	43.8			
Aluminum		µg/L	25	BRL			
Antimony		µg/L	2	BRL			
Arsenic	10	µg/L	1	BRL			
Barium		µg/L	5	29.7			
Beryllium		µg/L	1	BRL			
Cadmium		µg/L	1	BRL			
Calcium		mg/L	5	30.5			
Chromium		µg/L	1	BRL			
Cl2, Free		mg/L	0.1				
Conductivity		umhos/cm	10	587.6			
Copper	1300	µg/L	1	3.5			
Hardness		mg/L	5	92.0			
Iron		µg/L	5	BRL			
Lead	15	µg/L	1	BRL			
Manganese		µg/L	5	5.3			
Nickel		µg/L	1	1.1			
NO2	1	mg/L	0.02	0.0			
NO2+NO3	10	mg/L	0.2	0.9			
NO3	10	mg/L	0.18	0.9			
o-PO4		mg/L	0.05	1.5			
o-PO4 as P		mg/L	Calc	0.5			
Selenium	50	µg/L	1	BRL			
Silver		µg/L	5	BRL			
Sodium		mg/L	2	67.6			
Temperature		°C	-10	5.1			
Thallium		µg/L	1	BRL			
Total HAA			1	3.0			
Total THM	80	µg/L	0.5	6.5			
Turbidity		NTU	0.1	BRL			
Zinc		µg/L	5	BRL			

MCL = Maximum Contamination Level
 mg/L = milligrams per liter, parts per million
 SU = Standard Units
 C = Celcius
 µg/L = micrograms per liter, parts per billion
 NTU = Nephelometric Turbidity Units
 umhos/cm = micromhos per centimeter
 RL = Reporting Limit
 BRL = Below Reporting Limit
 Note: some of the data is averaged and based on multiple collections.



Certified Water Testing

VELAP ID: 460012 1851 Rippon Boulevard
 VA DW ID: 00240 Woodbridge, VA 22191
 EPA ID: VA00050 703-393-2071

Average Point of Entry Analytical Report 2022

Point of Entry: 14329 Glenkirk Road (West)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	40.4			
Aluminum		µg/L	25	BRL			
Antimony		µg/L	2	BRL			
Arsenic	10	µg/L	1	BRL			
Barium		µg/L	5	24.9			
Beryllium		µg/L	1	BRL			
Cadmium		µg/L	1	BRL			
Calcium		mg/L	5	21.6			
Chromium		µg/L	1	BRL			
Cl2, Free		mg/L	0.1				
Conductivity		umhos/cm	10	289.0			
Copper	1300	µg/L	1	1.8			
Hardness		mg/L	5	62.0			
Iron		µg/L	5	BRL			
Lead	15	µg/L	1	BRL			
Manganese		µg/L	5	BRL			
Nickel		µg/L	1	BRL			
NO2	1	mg/L	0.02	0.0			
NO2+NO3	10	mg/L	0.2	BRL			
NO3	10	mg/L	0.18	BRL			
o-PO4		mg/L	0.05	1.3			
o-PO4 as P		mg/L	Calc	0.4			
Selenium	50	µg/L	1	BRL			
Silver		µg/L	5	BRL			
Sodium		mg/L	2	28.8			
Temperature		°C	-10	5.3			
Thallium		µg/L	1	BRL			
Total HAA			1	15.0			
Total THM	80	µg/L	0.5	20.6			
Turbidity		NTU	0.1	0.2			
Zinc		µg/L	5	BRL			

MCL = Maximum Contamination Level
 mg/L = milligrams per liter, parts per million
 SU = Standard Units
 C = Celcius
 µg/L = micrograms per liter, parts per billion
 NTU = Nephelometric Turbidity Units
 µmhos/cm = micromhos per centimeter
 RL = Reporting Limit
 BRL = Below Reporting Limit
 Note: some of the data is averaged and based on multiple collections.



Certified Water Testing

VELAP ID: 460012 1851 Rippon Boulevard
 VA DW ID: 00240 Woodbridge, VA 22191
 EPA ID: VA00050 703-393-2071

Average Point of Entry Analytical Report 2022

Point of Entry: 8230 Patton Lane (West)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	74.1			
Aluminum		µg/L	25	BRL			
Antimony		µg/L	2	BRL			
Arsenic	10	µg/L	1	BRL			
Barium		µg/L	5	33.6			
Beryllium		µg/L	1	BRL			
Cadmium		µg/L	1	BRL			
Calcium		mg/L	5	33.7			
Chromium		µg/L	1	BRL			
Cl2, Free		mg/L	0.1				
Conductivity		umhos/cm	10	465.7			
Copper	1300	µg/L	1	1.5			
Hardness		mg/L	5	128.0			
Iron		µg/L	5	BRL			
Lead	15	µg/L	1	BRL			
Manganese		µg/L	5	BRL			
Nickel		µg/L	1	1.2			
NO2	1	mg/L	0.02	0.0			
NO2+NO3	10	mg/L	0.2	1.2			
NO3	10	mg/L	0.18	1.1			
o-PO4		mg/L	0.05	1.4			
o-PO4 as P		mg/L	Calc	0.4			
Selenium	50	µg/L	1	BRL			
Silver		µg/L	5	BRL			
Sodium		mg/L	2	34.7			
Temperature		°C	-10	3.9			
Thallium		µg/L	1	BRL			
Total HAA			1	2.0			
Total THM	80	µg/L	0.5	4.6			
Turbidity		NTU	0.1	0.1			
Zinc		µg/L	5	BRL			

MCL = Maximum Contamination Level
 mg/L = milligrams per liter, parts per million
 SU = Standard Units
 C = Celcius
 µg/L = micrograms per liter, parts per billion
 NTU = Nephelometric Turbidity Units
 umhos/cm = micromhos per centimeter
 RL = Reporting Limit
 BRL = Below Reporting Limit
 Note: some of the data is averaged and based on multiple collections.