

**PWCSA CAPITAL IMPROVEMENT PROJECT DATA SHEET**

**PROJECT INFORMATION**

**Project Name:** New Robert Trent Jones Booster Pumping Station Suction Main (F09)

**CIP Number:** WSUP-113

**JDE Number(s):** Not Assigned

**Location:** Glenkirk Rd. to Robert Trent Jones BPS

**Pressure Zone:** HM – Haymarket

**Sewershed:** BR – Broad Run

**Magisterial District:** BR – Brentsville

**Criteria:** 1, 3, 5

**Project Estimate:** Order of Magnitude

**Estimate By:** Engineering and Planning Division


**PROJECT DESCRIPTION**

**Project Description:** Construction of approximately 5,800-feet of 24-inch water main to replace the existing 18-inch main on the suction side of the Robert Trent Jones Booster Pump Station, F-09.

**Project Benefit:** This project will help maintain system pressures on the suction side of the station when it is in operation.

**Source Derivation:** Operations & Maintenance Division, and Engineering and Planning Division

**PROJECT PICTURE**



This CIP is marked as a future project.

| Proposed Funding Sources |             |
|--------------------------|-------------|
| Expansion Fund (02)      | -           |
| Commitment Fund (03)     | -           |
| Replacement Fund (04)    | 100%        |
| Other Contribution       | -           |
| <b>PROJECT TOTAL</b>     | <b>100%</b> |