

# PWCSA Hydrant Flow Report

## General Information


Location:	7400 Infantry Ridge Road	Date:	2-7-2019
Service Level:	Gainesville / Wellington	Time:	1:00 p.m.
High/Low HGL:	457 / 437	Test By:	TR/CH

## Static Hydrant Information

Map Number:	098	Static Hydrant Number:	124
Manufacturer:	Mueller	Static Pressure:	84 psi
Year Manufactured:	2000	Residual Pressure:	80 psi

## Flow Hydrant Information

Map Number:	098	Flow Hydrant Number:	121
Manufacturer:	Mueller	Flow Rate:	1300 gpm
Year Manufactured:	2000	Pitot Pressure:	60 psi



\*\* The Prince William County Service Authority is not responsible for assumptions, calculations, or designs made based on the results of this test. Please note that the flows available from these hydrants are subject to changes or operational variations in the PWCSA's water system. You are requested to apply these results exercising professional judgment and employing the help of an accurate hydraulic computer model\*\*

Report generated on: February 7, 2019